

May 2012



L20 SAMPLE SPECIFICATION X-RAY NONE FIRE RATED DOORSET

Components

INTERNAL X-RAY NONE FIRE RATED TIMBER DOORSETS:

Product Data Sheet reference: PDS8 Series 8

Manufacturer: Noberne Doors Ltd, Lupton Street, Hunslet, Leeds LS10 2QP

telephone: 0113 277 8577, email: sales@nobernedoors.co.uk

Door leaf:

Core: Solid core incorporating lead insert

Door Thickness: 46mm thick for none fire rated

Facing: (4mm MDF/veneer/laminate)

Lipping: (Visible/Concealed) 6mm hardwood lipping to all edges

Glazing details: None fire rated doors to be factory glazed with lead equivalent glass and and pinned hardwood beads.

Finish as delivered: Factory finished (one coat primer to two faces/two coats factory lacquer to two faces)

Frame:

Wood species: Hardwood incorporating lead insert

Class (to BS EN 942): J40 and J50

Finish as delivered: (Primed for site painting/Sealer coat for site finish)

Preservative treatment: N/A

Moisture content on delivery: 9 to 13%

Architrave:

Wood Species: 69x18fs (MDF/Hardwood) lead backed architrave one side

Class (to BS EN 942): J40 and J50

Preservative treatment: N/A

Moisture content on delivery: 9 to 13%

Ironmongery:

Door hung in frame on Noberne BZP butt hinges 4 per door leaf

Perimeter seals:

N/A

Other requirements:

Fixing: In strict accordance with manufacturers instructions and BS8214 2008

All doors to be labelled with manufacturers metal foil labels

Please amend (items) as required. We would be happy to review or discuss your specification requirements. Telephone 0113 2778577 or Email sales@nobernedoors.co.uk